



TREZOR TEST s. r. o.
Na Vršku 67, 250 67 Klecany, Czech Republic

CERTIFICATION BODY No. 3025
ACCREDITED BY
THE CZECH ACCREDITATION INSTITUTE

CERTIFICATE OF CONFORMITY

Registration number: TT - 183/2022

for

JABLOTRON ALARMS a.s.
Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou

PRODUCT: Wireless access module with keypad and RFID
type JA-153E
including derived variant JA-153E-AN, JA-153E-GR, JA-153E-WH
with optional accessories JA-192E or JA-192E-AN or JA-192E-GR or JA-
192E-WH (Control segment of access modules)
Producer: JABLOTRON ALARMS a.s.
Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou, Czech Republic
CZ-CPA 27.90.11

CLASSIFICATION: The product is in accordance with the certification schema CS TT 5/2020
(based on scheme 5 EN ISO/IEC 17067:2013, based on testing and PMS audit).

and in conformity with requirements of

EN 50131-1:2006/A1:2009/A2:2017/A3:2020, EN 50131-3:2009 article 8.1.1.,
8.1.2, 8.1.3, 8.1.4, 8.1.5, 8.3.1, 8.3.2, 8.3.2.2.1, 8.3.2.2.2, 8.3.2.3, 8.3.2.4, 8.3.3, 8.3.3.1,
8.3.3.2, 8.3.3.3, 8.3.3.4, 8.3.4, 8.3.5, 8.3.6, 8.3.7, 8.4.1, 8.4.1.2, 8.5, 8.5.1, 8.6, 8.7.1, 8.7.2.1,
8.7.2.2, 8.8, 8.9, 8.10, 10, EN 50131-5-3:2017, EN 50131-6:2017 article 4.3.3.3, tab. 3,4

Security Grade 2, Environmental Class II

The certificate is issued within the scope of accreditation granted by certificate No. 77/2022 issued by
ČIA on 14 February 2022 on the basis of amendment certification protocol No. CE 40/2021.

Chairman of the Certification board
CO No. 3025
Ing. Ladislav Polák

Deputy chairman of the Certification board
CO No. 3025
Ing. Daniela ČÍŽKOVÁ

Date of publication: 05.05.2021
Certification date: 05.05.2021
Certification expiration date: 25.02.2025



This Certificate of Conformity may be used and reproduced in unchanged form only.

Certification body No. 3025
Company TREZOR TEST s.r.o.
Na Vršku 67, 250 67 Klecany

Appendix 1 is an integral part of
the certificate no. TT - 183/2022
Page: 1 / 1

Certification report no. CE 40/2021 including its amendment was issued based on
evaluation of test report No.: 2021 9856 issued by accredited laboratory TESTALARM
PRAHA spol. s r.o. No.: 1172.

